



Pool Closure Issues
With
Immediate \$716 Assessment

(As of July 1, 2009)

- 1. Loose, damaged or missing Main drain covers**
- 2. Water clarity (Turbidity)**
- 3. Missing or inadequate depth markers**
- 4. Non-functional re-circulating systems**
- 5. Non-compliant enclosures**
- 6. Fecal Matter**
- 7. GFCI (Lighting) If GFCI**
Note: If GFCI is not working properly, and there is water in the fixture, the body of water will be closed and a re-opening fee will be assessed. If GFCI is properly tripped, or can be tripped, the body of water will be closed, with no fee assessed.
- 8. No detectable disinfectant**
- 9. Complete absence of life saving equipment, and inadequate or no lifeguard coverage**

Other current closure items will remain in effect, however there will not be an immediate fee assessed.